GENERAC[®]

GUARDIAN® SERIES Residential Standby Generators Air-Cooled Gas Engine

Model 005914-1 (Steel) - 8 kVA 50Hz

Model 005915-1 (Steel) - 10 kVA 50Hz

Model 005916-1 (Steel) - 13 kVA 50Hz

Standby Power Rating

1 of 4

INCLUDES:

- Two Line LCD Tri-Lingual Digital Nexus™ Controller (English/Spanish/French)
- Electronic Governor

8/10/13kVA

- External Main Circuit Breaker, System Status & Maintenance Interval LED Indicators
- Sound Attenuated Enclosure
- Flexible Fuel Line
- Composite Mounting Pad
- Natural Gas or LP Gas Operation
- 1 Year/1000 Hour Limited Warranty



FEATURES

INNOVATIVE DESIGN & PROTOTYPE TESTING are key components of Generac's success in "IMPROVING POWER BY DESIGN." But it doesn't stop there. Total commitment to component testing, reliability testing, environmental testing, destruction and life testing, allows you to choose Generac with the confidence that these systems will provide superior performance.

O TEST CRITERIA:

- PROTOTYPE TESTED
- MOTOR STARTING ABILITY
- SYSTEM TORSIONAL TESTED

- SOLID-STATE, FREQUENCY COMPENSATED VOLTAGE REGULATION: This state-of-the-art power maximizing regulation system is standard on all Generac models. It provides optimized FAST RESPONSE to changing load conditions and MAXIMUM MOTOR STARTING CAPABILITY by electronically torque-matching the surge loads to the engine.
- **SINGLE SOURCE SERVICE RESPONSE** from Generac's dealer network provides parts and service know-how for the entire unit, from the engine to the smallest electronic component.



2 of 4

8/10/13kVA

Engine

features and benefits

Lingine	
• Generac (OHVI) Design	Maximizes engine "breathing" for increased fuel efficiency. Plateau honed cylinder walls and plasma moly rings helps the engine run cooler, reducing oil consumption resulting in longer engine life.
• "Spiny-lok" cast iron cylinder walls	Rigid construction and added durability provide long engine life.
• Electronic ignition/spark advance	These features combine to assure smooth, quick starting every time.
•Full pressure lubrication system	Pressurized lubrication to all vital bearings means better performance, less maintenance and longer engine life. Now featuring a 2 year/200 hour oil change interval.
•Low oil pressure shutdown system	Superior shutdown protection prevents catastrophic engine damage due to low oil.
High temperature shutdown	Prevents damage due to overheating.
Generator	
• Revolving field	Allows for a smaller, light weight unit that operates 25% more efficiently than a revolving armature generator.
 Skewed stator 	Produces a smooth output waveform for compatibility with electronic equipment.
Displaced phase excitation	Maximizes motor starting capability.
Automatic voltage regulation	Regulates the output voltage to $\pm 1\%$ prevents damaging voltage spikes.
Nexus [™] Controls	
Auto/Off/Manual switch	Selects the operating mode.
Utility voltage sensing	Constantly monitors utility voltage, setpoints 60% dropout, 80% pick-up, of standard voltage.
• Utility interrupt delay	Prevents nuisance start-ups of the engine, adjustable 10-30 seconds.
•Engine warm-up	Ensures engine is ready to assume the load, setpoint approximately 5 seconds.
• Engine cool-down	Allows engine to cool prior to shutdown, setpoint approximately 1 minute.
Programmable seven day exerciser	Operates engine to prevent oil seal drying and damage between power outages by running the generator for 12 minutes every week.
Smart battery charger	Delivers charge to the battery only when needed at varying rates depending on outdoor air temperature.
Main Line Circuit Breaker	Protects generator from overload.
• Electronic governor	Maintains constant 50 Hz frequency.
Unit	
Weather protective enclosure	Ensures protection against mother nature. Hinged key locking roof panel for security. Lift-out front for easy acces to all routine maintenance items. Electrostatically applied textured epoxy paint for added durability.
• Enclosed critical grade muffler	Quiet, critical grade muffler is mounted inside the unit to prevent injuries.
 Small, compact, attractive 	Makes for an easy, eye appealing installation.

- •1' Flexible Fuel Line Connector
- Composite Mounting Pad

Easy Installation.

GENERAC

8/10/13kVA

specifications

Generator Model	005914-1 (8 kVA)	005915-1 (10 kVA)	005916-1 (13 kVA)
Rated Maximum Continuous Power Capacity (LP)	8,000 VA*	10,000 VA*	13,000 VA*
Rated Maximum Continuous Power Capacity (NG)	7.000 VA**	10,000 VA**	13,000 VA**
Rated Voltage	220	220	220
Rated Voltage Rated Maximum Continuous Load Current – 220 Volts, Single Phase	36.4 LP/31.8 NG	45.5 LP/45.5 NG	59 LP/59 NG
Vain Line Circuit Breaker	40 Amp	50 Amp	60 Amp
^D hase	1 2	1	1 2
Number of Rotor Poles	=		=
Rated AC Frequency	50Hz	50Hz	50Hz
Power Factor	1	1	1
Battery Requirement (not included)		Volts and 525 Cold-cranking Am	
Unit Weight (Pounds/Kilos)	387/175.4	425.5/193	445/201.8
Dimensions (L x W x H) Inches/mm		48 x 25 x 29/1218 x 638 x 732	
Sound output in dB(A) at 23 ft. with generator operating at normal load	60	60	60
ingine			
Type of Engine	GENERAC OHVI V-TWIN	GENERAC OHVI V-TWIN	GENERAC OHVI V-TWIN
Number of Cylinders	2	2	2
Displacement	530cc	992cc	992cc
Jispiacement			
Culiadar Plank	Aluminum w/Cast	Aluminum w/Cast	Aluminum w/Cast
Cylinder Block	Iron Sleeve	Iron Sleeve	Iron Sleeve
Valve Arrangement	Overhead Valve	Overhead Valve	Overhead Valve
Ignition System	Solid-state Magneto	Solid-state Magneto	Solid-state Magneto
Governor System	Electronic	Electronic	Electronic
Compression Ratio	9.5:1	9.5:1	9.5:1
Starter	12 Vdc	12 Vdc	12 Vdc
Oil Capacity Including Filter	1.7/1.6	1.9/1.8	1.9/1.8
Operating RPM	3,000	3,000	3,000
Full Load Liquid Propane ft ³ /hr (gal/hr) [Liter/hr] 1/2 Load	156 (4.42) 46 (1.25)/1.3 (4.73)	220 (6.23) 58 (1.56)/1.64 (5.9)	261 (7.39) 59 (1.61)/1.67 (6.1)
	70 (1.93)/1.98 (7.49) 7 inches of water column for nati		94 (2.57)/2.66 (9.7) er column for LP gas
*Required fuel pressure to generator fuel inlet at all load ranges - 5 to	70 (1.93)/1.98 (7.49) 7 inches of water column for natu and 2520 Btu per cubic feet with	ural gas, 11 to 14 inches of wate LP	
*Required fuel pressure to generator fuel inlet at all load ranges - 5 to **Outputs are based upon values @ 1000 Btu per cubic feet with NG @ 35,314.7 Btu per cubic meter w	70 (1.93)/1.98 (7.49) 7 inches of water column for natu and 2520 Btu per cubic feet with	ural gas, 11 to 14 inches of wate LP	
*Required fuel pressure to generator fuel inlet at all load ranges - 5 to **Outputs are based upon values @ 1000 Btu per cubic feet with NG @ 35,314.7 Btu per cubic meter w Controls	70 (1.93)/1.98 (7.49) 97 inches of water column for natu 6 and 2520 Btu per cubic feet with 7/100 vith NG and 88,993 Btu per cubic r	ural gas, 11 to 14 inches of wate LP	er column for LP gas
*Required fuel pressure to generator fuel inlet at all load ranges - 5 to **Outputs are based upon values @ 1000 Btu per cubic feet with NG	70 (1.93)/1.98 (7.49) 97 inches of water column for natu 6 and 2520 Btu per cubic feet with 7/100 vith NG and 88,993 Btu per cubic r	ural gas, 11 to 14 inches of wate LP neter with LP	er column for LP gas
*Required fuel pressure to generator fuel inlet at all load ranges - 5 to **Outputs are based upon values @ 1000 Btu per cubic feet with NG @ 35,314.7 Btu per cubic meter w Controls 2-Line Plain Text LCD Display	70 (1.93)/1.98 (7.49) o 7 inches of water column for natu G and 2520 Btu per cubic feet with vith NG and 88,993 Btu per cubic r Sin	ural gas, 11 to 14 inches of wate LP neter with LP	er column for LP gas
*Required fuel pressure to generator fuel inlet at all load ranges - 5 to **Outputs are based upon values @ 1000 Btu per cubic feet with NG @ 35,314.7 Btu per cubic meter w Controls 2-Line Plain Text LCD Display Mode Switch	70 (1.93)/1.98 (7.49) o 7 inches of water column for natu G and 2520 Btu per cubic feet with vith NG and 88,993 Btu per cubic r Sin Auton	ural gas, 11 to 14 inches of wate LP neter with LP nple user interface for ease of operati	on.
*Required fuel pressure to generator fuel inlet at all load ranges - 5 to **Outputs are based upon values @ 1000 Btu per cubic feet with NG @ 35,314.7 Btu per cubic meter w Controls 2-Line Plain Text LCD Display Mode Switch -Auto	70 (1.93)/1.98 (7.49) o 7 inches of water column for natu G and 2520 Btu per cubic feet with vith NG and 88,993 Btu per cubic r Sin Sin Auton Stops unit. Pi	ural gas, 11 to 14 inches of wate LP neter with LP nple user interface for ease of operati natic Start on Utility failure. 7 day exe	on. rciser. still operate.
*Required fuel pressure to generator fuel inlet at all load ranges - 5 to **Outputs are based upon values @ 1000 Btu per cubic feet with NG @ 35,314.7 Btu per cubic meter w Controls 2-Line Plain Text LCD Display Mode Switch -Auto -Off -Manual/Test (start)	70 (1.93)/1.98 (7.49) o 7 inches of water column for natu G and 2520 Btu per cubic feet with vith NG and 88,993 Btu per cubic r Sin Sin Auton Stops unit. Pi	aral gas, 11 to 14 inches of wate LP neter with LP nple user interface for ease of operati natic Start on Utility failure. 7 day exe ower is removed. Control and charger rol, unit stays on. If utility fails, transf	on. rciser. still operate.
 *Required fuel pressure to generator fuel inlet at all load ranges - 5 to **Outputs are based upon values @ 1000 Btu per cubic feet with NG @ 35,314.7 Btu per cubic meter w Controls 2-Line Plain Text LCD Display Mode Switch -Auto -Off -Manual/Test (start) Programmable start delay between 10-30 seconds 	70 (1.93)/1.98 (7.49) o 7 inches of water column for natu G and 2520 Btu per cubic feet with vith NG and 88,993 Btu per cubic r Sin Sin Auton Stops unit. P Start with starter contu	ural gas, 11 to 14 inches of wate LP neter with LP nple user interface for ease of operati natic Start on Utility failure. 7 day exe ower is removed. Control and charger rol, unit stays on. If utility fails, transf Standard	on. rciser. • still operate. er to load takes place.
 *Required fuel pressure to generator fuel inlet at all load ranges - 5 to **Outputs are based upon values @ 1000 Btu per cubic feet with NG @ 35,314.7 Btu per cubic meter w Controls 2-Line Plain Text LCD Display Mode Switch -Auto -Off -Manual/Test (start) Programmable start delay between 10-30 seconds Engine Start Sequence 	70 (1.93)/1.98 (7.49) o 7 inches of water column for natu G and 2520 Btu per cubic feet with vith NG and 88,993 Btu per cubic r Sin Sin Auton Stops unit. P Start with starter contu	aral gas, 11 to 14 inches of wate LP neter with LP nple user interface for ease of operati natic Start on Utility failure. 7 day exe ower is removed. Control and charger rol, unit stays on. If utility fails, transf	on. rciser. • still operate. er to load takes place.
 *Required fuel pressure to generator fuel inlet at all load ranges - 5 to **Outputs are based upon values @ 1000 Btu per cubic feet with NG @ 35,314.7 Btu per cubic meter w Controls 2-Line Plain Text LCD Display Mode Switch -Auto -Off -Manual/Test (start) Programmable start delay between 10-30 seconds Engine Start Sequence Engine Warm-up 	70 (1.93)/1.98 (7.49) o 7 inches of water column for natu G and 2520 Btu per cubic feet with vith NG and 88,993 Btu per cubic r Sin Sin Auton Stops unit. P Start with starter contu	ural gas, 11 to 14 inches of wate LP neter with LP natic Start on Utility failure. 7 day exe ower is removed. Control and charger rol, unit stays on. If utility fails, transf Standard ug: 16 sec. on, 7 rest (90 sec. maxim 5 seconds	on. rciser. • still operate. er to load takes place.
*Required fuel pressure to generator fuel inlet at all load ranges - 5 to **Outputs are based upon values @ 1000 Btu per cubic feet with NG @ 35,314.7 Btu per cubic meter w Controls 2-Line Plain Text LCD Display Mode Switch -Auto -Off -Manual/Test (start) Programmable start delay between 10-30 seconds Engine Start Sequence Engine Warm-up Engine Cool-Down	70 (1.93)/1.98 (7.49) o 7 inches of water column for natu G and 2520 Btu per cubic feet with vith NG and 88,993 Btu per cubic r Sin Auton Stops unit. P Start with starter contu Cyclic crankir	aral gas, 11 to 14 inches of wate LP neter with LP natic Start on Utility failure. 7 day exe power is removed. Control and charger rol, unit stays on. If utility fails, transf Standard ng: 16 sec. on, 7 rest (90 sec. maxim 5 seconds 1 minute	on. rciser. • still operate. er to load takes place. ium duration).
*Required fuel pressure to generator fuel inlet at all load ranges - 5 to **Outputs are based upon values @ 1000 Btu per cubic feet with NG @ 35,314.7 Btu per cubic meter w Controls 2-Line Plain Text LCD Display Mode Switch -Auto -Off -Manual/Test (start) Programmable start delay between 10-30 seconds Engine Start Sequence Engine Warm-up Engine Cool-Down Starter Lock-out	70 (1.93)/1.98 (7.49) o 7 inches of water column for natu G and 2520 Btu per cubic feet with vith NG and 88,993 Btu per cubic r Sin Auton Stops unit. P Start with starter contu Cyclic crankir	ural gas, 11 to 14 inches of wate LP neter with LP nple user interface for ease of operati natic Start on Utility failure. 7 day exe power is removed. Control and charger rol, unit stays on. If utility fails, transf Standard ng: 16 sec. on, 7 rest (90 sec. maxim 5 seconds 1 minute tr e-engage until 5 sec. after engine	on. rciser. • still operate. er to load takes place. ium duration).
 *Required fuel pressure to generator fuel inlet at all load ranges - 5 to **Outputs are based upon values @ 1000 Btu per cubic feet with NG @ 35,314.7 Btu per cubic meter w Controls 2-Line Plain Text LCD Display Mode Switch -Auto -Off -Manual/Test (start) Programmable start delay between 10-30 seconds Engine Start Sequence Engine Warm-up Engine Cool-Down Starter Lock-out Smart Battery Charger 	70 (1.93)/1.98 (7.49) o 7 inches of water column for natu G and 2520 Btu per cubic feet with vith NG and 88,993 Btu per cubic r Sin Auton Stops unit. P Start with starter contu Cyclic crankir	aral gas, 11 to 14 inches of wate LP neter with LP natic Start on Utility failure. 7 day exe power is removed. Control and charger rol, unit stays on. If utility fails, transf Standard ng: 16 sec. on, 7 rest (90 sec. maxim 5 seconds 1 minute t re-engage until 5 sec. after engine Standard	on. rciser. • still operate. er to load takes place. ium duration).
 *Required fuel pressure to generator fuel inlet at all load ranges - 5 to **Outputs are based upon values @ 1000 Btu per cubic feet with NG @ 35,314.7 Btu per cubic meter w Controls 22-Line Plain Text LCD Display Mode Switch -Auto -Off -Manual/Test (start) Programmable start delay between 10-30 seconds Engine Start Sequence Engine Cool-Down Starter Lock-out Starter Lock-out Starter Lock-out Starter Lock-out Control With Over and Under Voltage Protection	70 (1.93)/1.98 (7.49) o 7 inches of water column for natu G and 2520 Btu per cubic feet with vith NG and 88,993 Btu per cubic r Sin Auton Stops unit. P Start with starter contu Cyclic crankir	aral gas, 11 to 14 inches of wate LP neter with LP natic Start on Utility failure. 7 day exe power is removed. Control and charger rol, unit stays on. If utility fails, transf Standard ng: 16 sec. on, 7 rest (90 sec. maxim 5 seconds 1 minute to re-engage until 5 sec. after engine Standard Standard Standard Standard	on. rciser. • still operate. er to load takes place. ium duration).
 *Required fuel pressure to generator fuel inlet at all load ranges - 5 to **Outputs are based upon values @ 1000 Btu per cubic feet with NG @ 35,314.7 Btu per cubic meter w Controls 22-Line Plain Text LCD Display Mode Switch -Auto -Off -Manual/Test (start) Programmable start delay between 10-30 seconds Engine Start Sequence Engine Cool-Down Starter Lock-out Starter Lock-out Starter Lock-out Starter Voltage Regulation with Over and Under Voltage Protection Automatic Low Oil Pressure Shutdown 	70 (1.93)/1.98 (7.49) o 7 inches of water column for natu G and 2520 Btu per cubic feet with vith NG and 88,993 Btu per cubic r Sin Auton Stops unit. P Start with starter contu Cyclic crankir	aral gas, 11 to 14 inches of wate LP neter with LP natic Start on Utility failure. 7 day exe power is removed. Control and charger rol, unit stays on. If utility fails, transf Standard ug: 16 sec. on, 7 rest (90 sec. maxim 5 seconds 1 minute the engage until 5 sec. after engine Standard Standard Standard Standard Standard	on. rciser. • still operate. er to load takes place. ium duration).
*Required fuel pressure to generator fuel inlet at all load ranges - 5 to **Outputs are based upon values @ 1000 Btu per cubic feet with NG @ 35,314.7 Btu per cubic meter w Controls 2-Line Plain Text LCD Display Mode Switch -Auto -Off -Manual/Test (start) Programmable start delay between 10-30 seconds Engine Start Sequence Engine Warm-up Engine Cool-Down Starter Lock-out Smart Battery Charger Automatic Voltage Regulation with Over and Under Voltage Protection Automatic Low Oil Pressure Shutdown Overspeed Shutdown	70 (1.93)/1.98 (7.49) o 7 inches of water column for natu G and 2520 Btu per cubic feet with vith NG and 88,993 Btu per cubic r Sin Auton Stops unit. P Start with starter contu Cyclic crankir	aral gas, 11 to 14 inches of wate LP neter with LP natic Start on Utility failure. 7 day exe over is removed. Control and charger rol, unit stays on. If utility fails, transf Standard ug: 16 sec. on, 7 rest (90 sec. maxim 5 seconds 1 minute to re-engage until 5 sec. after engine Standard Standard Standard Standard Standard Standard Standard	on. rciser. • still operate. er to load takes place. ium duration).
*Required fuel pressure to generator fuel inlet at all load ranges - 5 to **Outputs are based upon values @ 1000 Btu per cubic feet with NG @ 35,314.7 Btu per cubic meter w Controls 2-Line Plain Text LCD Display Mode Switch -Auto -Off -Manual/Test (start) Programmable start delay between 10-30 seconds Engine Start Sequence Engine Warm-up Engine Cool-Down Starter Lock-out Smart Battery Charger Automatic Voltage Regulation with Over and Under Voltage Protection Automatic Low Oil Pressure Shutdown Overspeed Shutdown High Temperature Shutdown	70 (1.93)/1.98 (7.49) o 7 inches of water column for natu G and 2520 Btu per cubic feet with vith NG and 88,993 Btu per cubic r Sin Auton Stops unit. P Start with starter contu Cyclic crankir	aral gas, 11 to 14 inches of wate LP neter with LP natic Start on Utility failure. 7 day exe power is removed. Control and charger rol, unit stays on. If utility fails, transf Standard ug: 16 sec. on, 7 rest (90 sec. maxim 5 seconds 1 minute to re-engage until 5 sec. after engine Standard Standard Standard Standard Standard Standard Standard Standard Standard Standard Standard	on. rciser. • still operate. er to load takes place. ium duration).
 *Required fuel pressure to generator fuel inlet at all load ranges - 5 to **Outputs are based upon values @ 1000 Btu per cubic feet with NG @ 35,314.7 Btu per cubic meter w Controls 2-Line Plain Text LCD Display Mode Switch -Auto -Off -Manual/Test (start) Programmable start delay between 10-30 seconds Engine Start Sequence Engine Warm-up Engine Cool-Down Starter Lock-out Smart Battery Charger Automatic Voltage Regulation with Over and Under Voltage Protection Automatic Low Oil Pressure Shutdown Overspeed Shutdown Overcrank Protection 	70 (1.93)/1.98 (7.49) o 7 inches of water column for natu G and 2520 Btu per cubic feet with vith NG and 88,993 Btu per cubic r Sin Auton Stops unit. P Start with starter contu Cyclic crankir	aral gas, 11 to 14 inches of wate LP neter with LP natic Start on Utility failure. 7 day exe power is removed. Control and charger rol, unit stays on. If utility fails, transf Standard ug: 16 sec. on, 7 rest (90 sec. maxim 5 seconds 1 minute to re-engage until 5 sec. after engine Standard	on. rciser. • still operate. er to load takes place. ium duration).
 *Required fuel pressure to generator fuel inlet at all load ranges - 5 to **Outputs are based upon values @ 1000 Btu per cubic feet with NG @ 35,314.7 Btu per cubic meter w Controls 2-Line Plain Text LCD Display Mode Switch -Auto -Off -Manual/Test (start) Programmable start delay between 10-30 seconds Engine Start Sequence Engine Cool-Down Starter Lock-out Smart Battery Charger Automatic Voltage Regulation with Over and Under Voltage Protection Automatic Low Oil Pressure Shutdown Overspeed Shutdown Divercrank Protection 	70 (1.93)/1.98 (7.49) o 7 inches of water column for natu G and 2520 Btu per cubic feet with vith NG and 88,993 Btu per cubic r Sin Auton Stops unit. P Start with starter contu Cyclic crankir	aral gas, 11 to 14 inches of wate LP neter with LP natic Start on Utility failure. 7 day exe power is removed. Control and charger rol, unit stays on. If utility fails, transf Standard ug: 16 sec. on, 7 rest (90 sec. maxim 5 seconds 1 minute to re-engage until 5 sec. after engine Standard	on. rciser. • still operate. er to load takes place. ium duration).
*Required fuel pressure to generator fuel inlet at all load ranges - 5 to **Outputs are based upon values @ 1000 Btu per cubic feet with NG @ 35,314.7 Btu per cubic meter w Controls 2-Line Plain Text LCD Display Mode Switch -Auto -Off -Manual/Test (start) Programmable start delay between 10-30 seconds Engine Start Sequence Engine Warm-up Engine Cool-Down Starter Lock-out Smart Battery Charger Automatic Voltage Regulation with Over and Under Voltage Protection Automatic Low Oil Pressure Shutdown Overspeed Shutdown High Temperature Shutdown Overcrank Protection Safety Fused Low Battery Protection	70 (1.93)/1.98 (7.49) o 7 inches of water column for natu G and 2520 Btu per cubic feet with vith NG and 88,993 Btu per cubic r Sin Auton Stops unit. P Start with starter contu Cyclic crankir	aral gas, 11 to 14 inches of wate LP neter with LP nple user interface for ease of operati natic Start on Utility failure. 7 day exe ower is removed. Control and charger rol, unit stays on. If utility fails, transf Standard ng: 16 sec. on, 7 rest (90 sec. maxim 5 seconds 1 minute of re-engage until 5 sec. after engine Standard	on. rciser. • still operate. er to load takes place. ium duration).
 *Required fuel pressure to generator fuel inlet at all load ranges - 5 to **Outputs are based upon values @ 1000 Btu per cubic feet with NG @ 35,314.7 Btu per cubic meter w Controls 2-Line Plain Text LCD Display Mode Switch -Auto -Off -Manual/Test (start) Programmable start delay between 10-30 seconds Engine Start Sequence Engine Cool-Down Starter Lock-out Smart Battery Charger Automatic Voltage Regulation with Over and Under Voltage Protection Automatic Low Oil Pressure Shutdown Overspeed Shutdown Divercrank Protection Safety Fused Low Battery Protection 50 Event Run Log 	70 (1.93)/1.98 (7.49) o 7 inches of water column for natu G and 2520 Btu per cubic feet with vith NG and 88,993 Btu per cubic r Sin Auton Stops unit. P Start with starter contu Cyclic crankir	aral gas, 11 to 14 inches of wate LP neter with LP nple user interface for ease of operati natic Start on Utility failure. 7 day exe ower is removed. Control and charger rol, unit stays on. If utility fails, transf Standard ug: 16 sec. on, 7 rest (90 sec. maxim 5 seconds 1 minute of re-engage until 5 sec. after engine Standard	on. rciser. • still operate. er to load takes place. ium duration).
*Required fuel pressure to generator fuel inlet at all load ranges - 5 to **Outputs are based upon values @ 1000 Btu per cubic feet with NG @ 35,314.7 Btu per cubic meter w Controls 2-Line Plain Text LCD Display Mode Switch -Auto -Off -Manual/Test (start) Programmable start delay between 10-30 seconds Engine Start Sequence Engine Start Sequence Engine Cool-Down Starter Lock-out Smart Battery Charger Automatic Voltage Regulation with Over and Under Voltage Protection Automatic Low Oil Pressure Shutdown Overspeed Shutdown High Temperature Shutdown Overcrank Protection Safety Fused Low Battery Protection 50 Event Run Log Future Set Capable Exerciser	70 (1.93)/1.98 (7.49) o 7 inches of water column for natu G and 2520 Btu per cubic feet with vith NG and 88,993 Btu per cubic r Sin Auton Stops unit. P Start with starter contu Cyclic crankir	aral gas, 11 to 14 inches of wate LP neter with LP nple user interface for ease of operati natic Start on Utility failure. 7 day exe ower is removed. Control and charger rol, unit stays on. If utility fails, transf Standard ng: 16 sec. on, 7 rest (90 sec. maxim 5 seconds 1 minute tre-engage until 5 sec. after engine Standard	on. rciser. • still operate. er to load takes place. ium duration).
 *Required fuel pressure to generator fuel inlet at all load ranges - 5 to **Outputs are based upon values @ 1000 Btu per cubic feet with NG @ 35,314.7 Btu per cubic meter w Controls 2-Line Plain Text LCD Display Mode Switch -Auto -Off 	70 (1.93)/1.98 (7.49) o 7 inches of water column for natu G and 2520 Btu per cubic feet with vith NG and 88,993 Btu per cubic r Sin Auton Stops unit. P Start with starter contu Cyclic crankir	aral gas, 11 to 14 inches of wate LP neter with LP nple user interface for ease of operati natic Start on Utility failure. 7 day exe ower is removed. Control and charger rol, unit stays on. If utility fails, transf Standard ug: 16 sec. on, 7 rest (90 sec. maxim 5 seconds 1 minute of re-engage until 5 sec. after engine Standard	on. rciser. • still operate. er to load takes place. ium duration).

Rating definitions - Standby: Applicable for supplying emergency power for the duration of the utility power outage. No overload capability is available for this rating. (All ratings in accordance with BS5514, IS03046, DIN6271 and AS/NZS CISPR 12:2009). * Maximum wattage and current are subject to and limited by such factors as fuel Btu content, ambient temperature, altitude, engine power and condition, etc. Maximum power decreases about 3.5 percent for each 1,000 feet above sea level; and also will decrease about 1 percent for each 6° C (10° F) above 16° C (60°F). Sound output ratings from certain points on the generator subject to change based on installation parameters.

GENERAC


8/10/13kVA

available accessories

Model #	Product	Description
6212	Cold Weather Kit	If the temperature regularly falls below 32° F, install a cold weather kit to maintain optimal battery temperature. Kit consists of battery warmer with thermostat built into the wrap.
5839	Fascia Base Wrap Kit	The fascia base wrap snaps together around the bottom the new air-cooled generators. This offers a sleek, contoured appearance as well as offering protection from rodents and insects by covering the lifting holes located in the base.
5703	Paint Kit	Bisque Kit
5663 - 8kVA 5664 - 10 & 13kVA	Scheduled Maintenance Kit	Generac's scheduled maintenance kits provide all the hardware necessary to perform complete routine maintenance on a Generac automatic standby generator.
6621 - 8kVA 6620 - 10 & 13kVA	Extreme Cold Weather Kit	If the temperature regularly falls below 0 degrees F, install an extreme cold weather kit to maintain a non-freezing temperature in the engine breather. The kit consists of a breather warmer with thermostat built into the assembly.

dimensions

Design and specifications subject to change without notice. Dimensions shown are approximate. Contact your Generac dealer for certified drawings. DO NOT USE THESE DIMENSIONS FOR INSTALLATION PURPOSES.





4 of 4